

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER CERTIFICATE

No. 1592

Dated: 5-7-2025

It is certified that an inspection team headed by chemist, DLWTL, P.H. Division Jamui, from P.H Division, Jamui. Inspected the Kiran Heart Academy, Malaypur Barhat road. Nagdewa (Near Railway Station Jamui.) On 24.06.2025 checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

The above is valid for a period of Six Month.

Prin'
05.07.25

Signature with Seal

Name : Prince Kumar

Designation : Executive Engineer
Engineer of PHED

Name & Address of the Office/Department:
P.H. Division, Jamui.

To,

Principal

Kiran Heart Academy
Malaypur Barhat Road, Nagdewa.
(Near Railway Station, Jamui)

Government of Bihar
Public Health Engineering Department

District Name :- Jamui

Division Name :- Public Health Division, Jamui

Water Quality Test Report

Sample Collected by- School Staff

Date of Sampling:-24.06.2025

Physico-Chemical and Bacteriological Parameters						PH	Turb	EC	TDS	TH	Ca	Mg	Cl	Alkali.	NO3	F	T.Coli	Source of Water	Remarks
Unit						-	NTU	ymho/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	MPN/100 ml		
Sl. No	Block	Nagar Panchayat	Village	Ward No	Location Details														
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
1	Kiran Heart Academy, Malaypur Barhat Road, (Near Railway Station) Jamui				Boring - 1	7.56	1.44	547	356	174	40	14	42	182	3.56	0.313	NO	Tubewell	
Desirable Limit*						6.5-8.5	1.00	-	500	200	75	30	250	200.00	45	1.00	YES /NO		
Permissible Limit* in absence of alternate source						NR	5.00	-	2000	600	200	100	1000	600.00	NR	1.5			

Rajesh Kumar
Chemist 05/07/2025

P.H.Division, Jamui